



April 8, 2014

Rev. 8

Unigy HR

Typical Baseline Ohmic Values - On Float

Battery Type	Baseline Ohmic Values on Float			
	Midtronics** (Siemens)	Alber Cellcorder (milli-ohms)	Biddle BITE II (milli-ohms)	Biddle MBITE (milli-ohms)
U1HR1500	747	8.848	7.238	7.876
45HR2000	925	7.153	5.852	6.368
24HR3000	1319	5.014	4.102	4.464
27HR3500	1567	4.220	3.452	3.756
31HR4000	1926	3.433	2.808	3.056
31HR5000	1487	4.448	3.639	3.959
HR3000	1854	3.564	2.883	3.124
HR3500	2010	3.287	2.659	2.881
HR4000	2473	2.673	2.162	2.343
HR5500	2183	3.026	2.448	2.652
HR3500ET	1759	3.758	3.040	3.294
HR5500ET	2080	3.177	2.570	2.784
HR7500ET	2460	2.666	2.156	2.337
4DHR6500 ¹	2222	2.976	2.435	2.649
4DHR6500 ²	2639	2.504	2.026	2.195

4DHR6500¹ Lead Burn Post Design (Old)

4DHR6500² Epoxy Post Threaded Insert Design (Current)

- The above data are typical results and do not form a specification.
- Values are subject to change without notification.
- These values are not to be used to determine warranty claims.

** = Midtronics Meters include:
 Micro Celltron CTM-100
 Celltron Advance CTA-2000
 Celltron Ultra - CTU-6000